

**Minuteman High School
Remediation Plan – Lead Testing Results Over the Action Level (15 ug/L)
February 17, 2017**

Location	DEP Location Type	DEP Location Code	Pb Final	Pb Confirm	Action Taken
Kitchen – Two-Bay Sink, Tap B facing right	KC	012	27.1 ug/L	24.3 ug/L	Disconnected and removed from service.
Advanced Manufacturing – Drinking Fountain	WC	024	216 ug/L	167 ug/L	Disconnected and removed from service.
Restaurant – Large Kettle	KK	029	19.1 ug/L	16.4 ug/L	Immediately initiated protocol to flush before using.
Early Education & Care – Bubblers	DW	038	136 ug/L	103 ug/L	Disconnected and removed from service.
Early Education & Care – Bubblers	DW	038	42.8 ug/L	38.6 ug/L	Disconnected and removed from service.
Fountain, North Hallway between the Superintendent’s Office and Business Office	WC	043	19.4 ug/L	17 ug/L	Disconnected and removed from service.
Special Education, 3 rd floor – Sink 1, Room 3S10	CF	045	37.6 ug/L	36.2 ug/L	Installed “Hand Washing Only” sign over sink.
Special Education, 3 rd floor – Sink 2, Room 3S10	CF	046	30.9 ug/L	26.6 ug/L	Installed “Hand Washing Only” sign over sink.
Health Occupations – Sink 2 (Room 3522)	CF	049	14 ug/L	12.4 ug/L	Installed “Hand Washing Only” sign over sink.
Health Occupations – Sink (Room 3523)	KC	051	39 ug/L	35.8 ug/L	Installed “Hand Washing Only” sign over sink.
Health Occupations – Sink (Room 3523)	KC	051	156 ug/L	109 ug/L	Installed “Hand Washing Only” sign over sink.
Tremont School building – Sink in Room 132	CF	067P	30.4 ug/L	26.1 ug/L	Installed “Hand Washing Only” sign over sink.

This document is based on water testing analysis conducted by the Massachusetts Water Resources Authority (MWRA) Department of Laboratory Services. Water samples were taken in January of 2017 from a total of 108 water taps at the main Minuteman High School building in Lexington, property owned by Minuteman at 22 Mill Street in Lincoln, and property owned by Minuteman and currently occupied by the Tremont School in Lexington.